

8-7-15 Available Water Storage PWS Impacted by Gold King Release			Updated 8/10/15 6:05 PM CT		# of Days of Water Available	System Contact
PWS ID #	System Name	Sources	Physical Storage noted in the call to the system	Population		
NM3509824	Aztec Domestic Water System	Animas R. only; inactive connection to Bloomfield	Per Tyrone Begay: Plume arrived at about midnight. EPA collected samples at the facility at 8:00am this morning. News/print media coverage has been extensive.	6800	10 days	Tyrone Begay, Weekend Operator. Anthony 505 334-8684 (505 334-7612)
NM3510224	Farmington Water System	animas only; san juan intake is inactive	Per Jeff Engles, plant operator, pumps have been off for two days. They are aware/concerned storm events will remobilize deposited material and wonder about longer term actions/contingencies. 6000 ac/ft raw water storage in Farmington Lake/reservoir	47000	60 days	Bob Fredrickson 505 325-8949
NM3510324	Lower Valley WUA	San Juan only	Answering service receiving a "flood" of calls from public. Pumps off and storage revised to 15 day supply. Per Keith Lee: No plans to test river until main plume has passed. 30 million/gal with ave use of 1.5 million gallons/day	8428	8 days	Keith Lee 505 598-5585
NM3510524	Morningstar Water Supply System	animas only	Answering service receiving high call volume. Per Willis Manwill, Level II Operator: Plume arrived early this AM. Personnel taking grab samples for pH/turbidity. Public notice posted at office and drop box to provide latest info and urge conservation. Fire stations offering free water to public. Public information meeting scheduled at noon today at the Farmington Civic Center. 3 million finished/1.8 million raw	6423	7-14 days	Fred Whistle 505 325-2435 Willis Manwill, Level II Operator, cell 505 330-7011
NM3520024	Northstar WDWCA	animas only	Per Nate Yarbrow: Plume arrived at approx 6:00PM yesterday. Baseline pH in the river was 8.7. 7.8pH as plumes passed. 8.5pH this morning. Significant deposits in river (yellow/orange precipitates). Per Lloyd Ayliffe: Public informed via internet, phone, posters posted throughout Aztec (grocery stores, post office ect.), and 911 dispatch provided with two phone numbers for public to call. Lloyd concerned about aftermath of lingering precipitates/remobilization-whether normal flocculation will be sufficient. Public notification urges conservation. 15 million gallons	4123	45 days	Nate Yarbrow 505 334-9375 cell 505 486-5398 Lloyd Ayliffe 505 320-0718
NM3509924	Southside Mutual Domestic	one well + connection to Aztec	Per Rick Mitchell: Using Aztec water exclusively for time being. No change in well pH post plume. Public notice via call blast informing public water is safe to drink and directing them to the system's website which will be continually updated. 300,000 gallons + 66,000 from Aztec	1593	5 days but depends on Aztec	Rick Mitchell 505 303-1585 (also runs Flora Vista) Amy Rhoades 505 334-1414
NM3510624	Upper La Plata WUA	connection to Lower Valley WUA + inactive connection to farmington	Per Dwight James: All water currently from Lower Valley. Connection to Farmington is operable if necessary.	2265	no response	Dwight James 505 320-1356 Cherileen Henry (505)326-1751
NM3510024	Flora Vista	3 wells + connections to aztec and farmington	Per Rick Mitchell: Wells shut down. Water being received from Farmington with small percentage from Aztec. Same call blast notification as Southside above. 300,000 tank	4300	1 day but depend on Aztec	Rick Mitchell 505 303-1585
Total pop.				80,932		